CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0026:248 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Simplex Time Recorder, 100 Simplex Drive, Westminter, MA 01441

Contact: Paul D. Mattern (978) 731-8542 Fax (978) 731-8881

DESIGN: Models 4904-9174 through -9185 strobes, Models 4904-9345, -9346 synchronized strobes,

> and *Models 4905-9914 or 4905-9922 synchronized modules. Synchronized modules are required for synchronizing strobe lights if the interconnected control unit cannot provide synchronization itself. Refer to listee's data sheet for additional detailed product description

and operational considerations.

RATING: Electrical: **24 VDC**

> Candela: -9176, -9177, -9178, -9183, -9345: 15cd, 1Hz.

> > -9174, -9179, -9180, -9184, -9346: 30cd, 1Hz. -9175, -9181, -9182, -9185: 110cd, 1Hz.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobes for use with separately listed electrically compatible fire alarm control units. For

indoor use only. All models are for wall mount except for Models -9183, -9184, -9185, -9345 and

-9346 are for wall/ceiling mount.

*Rev. 02-18-2003 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

FEBRUARY 18, 2003 Date Issued: Listing Expires June 30, 2003

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager